

**Town of Andover  
Water Treatment Plant Laboratory  
Water Quality Test Results**

**SAMPLE REPORT**

Name: \_\_\_\_\_  
 Address: \_\_\_\_\_  
 Phone No. \_\_\_\_\_  
 Email Address: \_\_\_\_\_

Date and Time Sample Collected \_\_\_\_\_ *Notes re: Sample:* \_\_\_\_\_  
 Date Sample Delivered to Laboratory \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Test Parameters	Cold Tap	Hot Tap
Color	4	8
Turbidity (NTU)	0.26	0.51
pH <sup>1</sup>	8.72	8.53
Manganese (ppm) <sup>2, 3</sup>	ND <sup>4</sup>	0.0055
Iron (ppm) <sup>2</sup>	ND <sup>4</sup>	0.0072
<b>Bathroom Faucet</b>		
Lead (ppm) <sup>5</sup>	<0.0010	
Copper (ppm) <sup>6</sup>	0.0079	

**Notes**

- <sup>1</sup> The pH for Andover's water may be as high as 8.9 for corrosion control purposes.
- <sup>2</sup> The Secondary Maximum Contaminant Limits for aesthetic qualities for Manganese is 0.05 ppm, and 0.3 ppm for Iron.
- <sup>3</sup> The Lifetime Health Advisory (LHA) for Manganese, to protect against potential neurological effects, is 0.300 ppm.
- <sup>4</sup> ND - Non-Detected. The results are less than the detection limit of the instrumentation used.
- <sup>5</sup> The Action Level for Lead is 0.015 ppm.
- <sup>6</sup> The Action Level for Copper is 1.3 ppm.

Signature: \_\_\_\_\_  
 Date: \_\_\_\_\_